

COMMONWEALTH OF PENNSYLVANIA  
DEPARTMENT OF PUBLIC WELFARE

# CERTIFICATE OF COMPLIANCE

This Certificate is hereby granted to PRESBYTERIAN HOME IN THE PRESBYTERY OF HUNTINGDON

LEGAL ENTITY

To operate PRESBYTERIAN HOME

NAME OF FACILITY OR AGENCY

Located at 220 NEWRY STREET, HOLLIDAYSBURG, PA 16648

(COMPLETE ADDRESS OF FACILITY OR AGENCY)

ADDRESS OF SATELLITE SITE

ADDRESS OF SATELLITE SITE

ADDRESS OF SATELLITE SITE

ADDRESS OF SATELLITE SITE

ADDRESS OF SATELLITE SITE

ADDRESS OF SATELLITE SITE

To provide Personal Care Homes

TYPE OF SERVICE(S) TO BE PROVIDED

The total number of persons which may be cared for at one time may not exceed 50  
or the maximum capacity permitted by the Certificate of Occupancy, whichever is smaller.

(MAXIMUM CAPACITY)

Restrictions: \_\_\_\_\_

This certificate is granted in accordance with the Public Welfare Code of 1967, P. L. 31, as amended, and Regulations

55 Pa.Code Chapter 2600: Personal Care Homes

(MANUAL NUMBER AND TITLE OF REGULATIONS)

and shall remain in effect from May 27, 2010 until May 27, 2011,  
unless sooner revoked for non-compliance with applicable laws and regulations.

No: 343400

*Robert E. Robinson*

ISSUING OFFICER

*Kevin T. Casey*

DEPUTY SECRETARY

NOTE: This certificate is issued for the above site(s) only and is not transferable  
and should be posted in a conspicuous place in the facility.

PW 628 - 4/02



COMMONWEALTH OF PENNSYLVANIA  
DEPARTMENT OF PUBLIC WELFARE  
PO BOX 2675  
HARRISBURG, PENNSYLVANIA 17105-2675

ADULT RESIDENTIAL LICENSING

MAY 25 2010

PHONE: (717) 783-3670  
FAX: (717) 783-5662

Ms. Debra Larkin, Executive Director  
Presbyterian Home in the Presbytery of Huntingdon  
Presbyterian Home  
220 Newry Street  
Hollidaysburg, Pennsylvania 16648

Dear Ms. Larkin:

As a result of the Department of Public Welfare's licensing inspection on March 9, 2010 and the corrections you have made after our inspection, we have found the above personal care home to be in compliance with 55 Pa.Code Ch. 2600 (relating to Personal Care Homes). Therefore, a regular license is being issued. Your license is enclosed.

Sincerely,

A handwritten signature in cursive script that reads "Kevin T. Casey".

Kevin T. Casey  
Deputy Secretary

Enclosure  
License

**VIOLATION REPORT  
PERSONAL CARE HOMES – 55 Pa.Code Chapter 2600**

<b>NAME AND ADDRESS OF PERSONAL CARE HOME</b> PRESBYTERIAN HOME 220 NEWRY STREET HOLLIDAYSBURG, PA - 16648		<b>CURRENT LICENSE NUMBER</b> 343400	
<b>INSPECTION DATE(S) (Include all dates of the inspection)</b> March 9, 2010		<b>REGIONAL REPRESENTATIVE</b> Ron Minnich & Mike Palermo	
<b>SIGNATURE OF LEGAL ENTITY</b> <i>Nancy Dickson</i>	<b>DATE</b> 4/21/2010	<b>REGIONAL LICENSING APPROVAL OF PLAN OF CORRECTION</b> <i>Gloria Emick</i>	<b>DATE</b> 5/10/10

1 REGULATION 55 Pa.Code § 2600.	2 VIOLATION	3 DATE BY WHICH CORRECTION WILL BE COMPLETED	4 PLAN OF CORRECTION (include a step-by-step plan to correct the specific violation, as well as a plan to assure the violation does not recur)	5 DATE COMPLIANCE VERIFIED BY DPW
34 Heat sources, such as steam and hot heating pipes, water pipes, fixed space heaters, hot water heaters, and radiators, exceeding 120°F that are accessible to the resident, shall be equipped with protective guards or insulation to prevent the resident from coming in contact with the heat source.	The mechanical room located in the basement across from the beauty shop has a "hazardous area" sign posted on the door. The door was unlocked and accessible to residents. Inside the room, there was unprotected copper piping that extended out from the boiler and was extremely hot.	03/18/2010  <i>on-going be</i>	The mechanical room door that was not latched has been secured with a supply room lock set that uses a key to gain access but the key cannot be removed from the lock unless the door is latched and locked limiting access to staff who have a key. Moving forward the Director of Maintenance will routinely monitor access to the mechanical room to be sure it is secure.	5/10/10 <i>SE</i>
<b>APR 26 2010</b>				

**VIOLATION REPORT  
PERSONAL CARE HOMES – 55 Pa.Code Chapter 2600**

<b>NAME AND ADDRESS OF PERSONAL CARE HOME</b> PRESBYTERIAN HOME 220 NEWRY STREET HOLLIDAYSBURG, PA - 16648		<b>CURRENT LICENSE NUMBER</b> 343400	
<b>INSPECTION DATE(S) (Include all dates of the inspection)</b> March 9, 2010		<b>REGIONAL REPRESENTATIVE</b> Ron Minnich & Mike Palermo	
<b>SIGNATURE OF LEGAL ENTITY</b> <i>Nancy Dickson</i>	<b>DATE</b> 4/21/2010	<b>REGIONAL LICENSING APPROVAL OF PLAN OF CORRECTION</b> <i>Glenn Erick</i>	<b>DATE</b> 5/10/10

1 REGULATION 55 Pa.Code § 2600.	2 VIOLATION	3 DATE BY WHICH CORRECTION WILL BE COMPLETED	4 PLAN OF CORRECTION (include a step-by-step plan to correct the specific violation, as well as a plan to assure the violation does not recur)	5 DATE COMPLIANCE VERIFIED BY DPW
131f Fire extinguishers shall be inspected and approved annually by a fire safety expert. The date of the inspection shall be on the extinguisher.	The fire extinguisher located in the home's designated smoking area was not inspected by a fire safety expert, as required annually.	04/19/2010	The fire extinguisher located in the designated smoking area has been inspected by a fire safety expert and has been added to the preventative maintenance list. Moving forward, the designated smoking area will be monitored by the Assisted Living Manager.	5/10/10 BE