



COMMONWEALTH OF PENNSYLVANIA
DEPARTMENT OF PUBLIC WELFARE
PO BOX 2675
HARRISBURG, PENNSYLVANIA 17105-2675

ADULT RESIDENTIAL LICENSING

PHONE: (717) 783-3670
FAX: (717) 783-5662

CERTIFIED MAIL – RETURN RECEIPT REQUESTED
MAILING DATE: OCT 26 2010

Mr. George Hudic, Owner/Operator
Paraclete Group, LLC
421 Cottage Lane
Monroeville, Pennsylvania 15146

RE: George's Personal Care Home
108 Water Street
New Stanton, Pennsylvania 15672

Dear Mr. Hudic:

As a result of the Department of Public Welfare's licensing inspection on September 24, 2010 of the above personal care home, the violations with 55 Pa.Code Ch. 2600 (relating to Personal Care Homes) specified on the enclosed Violation Report were found.

Correction of these violations in accordance with the specified plan of correction is required. Failure to correct this violation may result in further licensing enforcement action.

Sincerely,

A handwritten signature in black ink, appearing to read "K.T. Casey".

Kevin T. Casey
Deputy Secretary

Enclosure
Violation Report

VIOLATION REPORT
PERSONAL CARE HOMES – 55 Pa.Code Chapter 2600

NAME AND ADDRESS OF PERSONAL CARE HOME George's Personal Care Home 108 Water Street, New Stanton, PA 15672		CURRENT LICENSE NUMBER 440572	
INSPECTION DATE(S) (Include all dates of the inspection) 09/24/2010		REGIONAL REPRESENTATIVE N. Mandock, J. Williams	
PRINTED NAME AND TITLE OF LEGAL ENTITY REPRESENTATIVE SIGNING PLAN OF CORRECTION (Required on FIRST PAGE only unless multiple representatives produce the plan)			
SIGNATURE OF LEGAL ENTITY REPRESENTATIVE	DATE	REGIONAL LICENSING APPROVAL OF PLAN OF CORRECTION	DATE

1 REGULATION 55 Pa.Code § 2600.	2 VIOLATION	3 DATE BY WHICH CORRECTION WILL BE COMPLETED	4 PLAN OF CORRECTION (include a step-by-step plan to correct the specific violation, as well as a plan to assure the violation does not recur)	5 DATE COMPLIANCE VERIFIED BY DPW
123c For a home serving 9 or more residents, an emergency evacuation diagram of each floor showing corridors, line of travel to exit doors and location of the fire extinguishers and pull signals shall be posted in a conspicuous and public place on each floor.	The home's first floor evacuation diagram does not include a floor plan of the entire first floor of the home. It lacks a diagram of the "older" existing part of the home with lines of travel to the exit doors and location of fire extinguishers.	11/15/2010 11/15/2010 11/15/2010	A new first floor emergency evacuation diagram will be developed to include all corridors and lines of travel to exit doors and the location of all fire extinguishers. It will be posted on the first floor. All staff persons and residents will be educated on the new emergency evacuation diagram. The administrator will check monthly to ensure the emergency evacuation diagrams are posted in a conspicuous and public place on each floor.	

VIOLATION REPORT
PERSONAL CARE HOMES – 55 Pa.Code Chapter 2600

NAME AND ADDRESS OF PERSONAL CARE HOME George's Personal Care Home 108 Water Street, New Stanton, PA 15672		CURRENT LICENSE NUMBER 440572		
INSPECTION DATE(S) (Include all dates of the inspection) 09/24/2010		REGIONAL REPRESENTATIVE N. Mandock, J. Williams		
PRINTED NAME AND TITLE OF LEGAL ENTITY REPRESENTATIVE SIGNING PLAN OF CORRECTION (Required on FIRST PAGE only unless multiple representatives produce the plan)				
SIGNATURE OF LEGAL ENTITY REPRESENTATIVE		DATE	REGIONAL LICENSING APPROVAL OF PLAN OF CORRECTION	DATE

1 REGULATION 55 Pa.Code § 2600.	2 VIOLATION	3 DATE BY WHICH CORRECTION WILL BE COMPLETED	4 PLAN OF CORRECTION (include a step-by-step plan to correct the specific violation, as well as a plan to assure the violation does not recur)	5 DATE COMPLIANCE VERIFIED BY DPW
144d Smoking outside of the smoking room is prohibited.	Approximately 14 cigarette butts were found in the home's driveway immediately next to the home's side entrance ramp. This area is not a designated smoking area for the home.	11/15/2010 11/15/2010 11/15/2010	The home will develop a new rule indicating that smoking outside of the designated area more than 3 times will make the resident eligible for discharge from the home. The rule will take effect 30 days after notice has been given to the residents. A designated staff person from each shift will monitor the grounds to ensure smoking is only occurring in the designated smoking area.	