



pennsylvania
DEPARTMENT OF PUBLIC WELFARE

APR 24 2014

Ms. Cynthia Mazza, VP/COO
Salisbury Behavioral Health Inc
Courtney 1, Suite 100
3894 Courtney Street
Bethlehem, Pennsylvania 18017

RE: Salisbury Behavioral Health Personal Care Home of Lehigh County
451 Lehigh Street
Allentown, Pennsylvania 18103
License #: 216740

Dear Ms. Mazza:

As a result of the Department of Public Welfare's licensing inspection on January 24, 2014, of the above facility, the violations with 55 Pa.Code Ch. 2600 (relating to Personal Care Homes) specified on the enclosed License Inspection Summary were found.

All violations specified on the enclosed License Inspection Summary must be corrected by the dates specified on the License Inspection Summary and continued compliance with 55 Pa.Code Ch. 2600 must be maintained.

Your regular license for the period March 26, 2014 to March 26, 2015 was issued on December 13, 2013. Your regular license remains in good standing.

Sincerely,

A handwritten signature in black ink, appearing to read "Matthew J. Jones", with a long horizontal flourish extending to the right.

Matthew J. Jones
Acting Director

Enclosure
License Inspection Summary

Violation Report: 21674 - 01/24/2014 - Rushin, Julianne
 PCH Name: SALISBURY BEHAVIORAL HEALTH PERSONAL CARE HOME OF LEHIGH CO

1. REGULATION 55 Pa. Code §2600
 2600.105(g)(1) - To reduce the risks of fire hazards, lint shall be removed from the lint trap and drum of clothes dryers after each use.

2a. DESCRIPTION OF VIOLATION
 There was an accumulation of lint, approximaetty 2 inches in diameter, in the lint trap of the clothes dryer in Laundry Room "C" posing a fire risk.

3. PLAN OF CORRECTION (POC) (Attach pages as necessary. Remember that you must sign and date any attached pages.)
 Include steps to correct the violation described above and steps to prevent a similar violation from occurring again. If steps cannot be completed immediately, include dates by which the steps will be completed.

There are currently signs posted in the laundry rooms to empty dryer lint after each use, but the signs are very small. The administrator has made larger, and more brightly colored signs to remind staff that they must remove all lint from the lint trap after each use. The administrator, Lynsey Reiss, and the Assistant Operations Director, [redacted] will hold a staff meeting on 02/13/2014 and have a fire safety training for all site staff. In particular, we will review with staff fire safety as it regards to the laundry room.

* The administrator shall be responsible for ongoing compliance.

[Signature]
 2/18/14

Repeat Violation: No Date(s) of Previous Violation(s):

Signature of Legal Entity Representative (Required on EVERY Page) *[Signature]*

Printed Name and Title of Legal Entity Representative (Required on EVERY Page) *Lynsey Reiss, Administrator* Date *2.5.14*

DEPARTMENT USE ONLY - HOMES MAY NOT WRITE BELOW THIS LINE!

The above plan of correction is approved as of <u>2/18/14</u> (Date)	Plan of correction implementation status as of <u>2/18/14</u> (Date)
The above plan of correction was approved by <i>[Signature]</i> (Initials)	<input type="checkbox"/> Fully Implemented <input checked="" type="checkbox"/> Partially Implemented - Adequate Progress <input type="checkbox"/> Partially Implemented - Inadequate Progress <input type="checkbox"/> Not Implemented

