



Ms. Barbara J. Trosiek-Kett, Administrator  
Michael M. Trosiek, Jr.  
P.O. Box 535  
New Salem, Pennsylvania 15468

MAR 26 2015

RE: Trosiek's Personal Care Home  
214 Second Street  
New Salem, Pennsylvania 15468  
Certificate #: 450260

Dear Ms. Trosiek-Kett:

Thank you for your request for a waiver of 55 Pa.Code Ch. 2600 (relating to personal care homes). You have requested a waiver of 55 Pa.Code § 2600.94(a) (relating to landings and stairs) for the above address.

A waiver of 55 Pa.Code § 2600.94(a) is not needed. According to § 2600.94(a), interior and exterior doors that open directly into a stairway and are used for exits doors, resident areas and fire exits must have a landing, which is a minimum of 3 feet by 3 feet. The Department determined the interior door leads to a stairway but does not open directly into a stairway. Trosiek's Personal Care Home must keep a copy of this documentation.

If you have any questions regarding the waiver process, you may contact the Operator Support Hotline at telephone number (866) 503-3926.

Sincerely,

A handwritten signature in black ink that reads "Tara Pride". The signature is written in a cursive, flowing style.

Tara Pride  
Director of Regulatory Implementation