



pennsylvania
DEPARTMENT OF HUMAN SERVICES

JUL 13 2017

Ms. Nanette Johnson,
Owner/Administrator
222 Salisbury Street
Meyersdale, Pennsylvania 15552

RE: Johnson's Personal Care Home
License #: 321370

Dear Ms. Johnson:

As a result of the Department of Human Services' annual licensing inspection on March 30, 2017 of the above facility, the violations with 55 Pa.Code Ch. 2600 (relating to Personal Care Homes) specified on the enclosed License Inspection Summary were found.

All violations specified on the enclosed License Inspection Summary must be corrected by the dates specified on the License Inspection Summary and continued compliance with 55 Pa.Code Ch. 2600 must be maintained.

In an effort to improve our licensing processes, the Bureau of Human Services Licensing is soliciting feedback about your recent human services licensing inspection experience. To participate in the online provider survey, launch your web browser and go to https://www.surveymonkey.com/r/BHSL_Inspection.

The survey is brief and will only take about 5 minutes to complete. Your participation in the survey is completely voluntary and all of your responses will be kept confidential. The responses will be reviewed as part of an aggregate of provider inspection responses. Thank you in advance for providing feedback.

Sincerely,

A handwritten signature in black ink, appearing to read "J. Rowe".

Jacqueline L. Rowe
Director

Enclosure
License Inspection Summary

Violation Report: 32137 - 03/30/2017 - Bomberger, Cybil
 PCH Name: JOHNSON S PERSONAL CARE HOME

1. REGULATION 55 Pa.Code §2600
 2600.89(b) - Hot water temperature in areas accessible to the resident may not exceed 120°F.

2a. DESCRIPTION OF VIOLATION
 On 3/30/17, at 2:55pm, the water temperature at the sink of the first floor "old side" bathroom measured 134 degrees Fahrenheit.

3. PLAN OF CORRECTION (POC) (Attach pages as necessary. Remember that you must sign and date any attached pages.)
 Include steps to correct the violation described above and steps to prevent a similar violation from occurring again. If steps cannot be completed immediately, include dates by which the steps will be completed.

We have turned both water tanks down, we are documenting and testing the water twice daily to make sure the temperature does not exceed 120°F. We have checked it for 2 weeks straight and will continue to check weekly starting now. Please see attached spread sheet.

Repeat Violation: No	Date(s) of Previous Violation(s):	
Signature of Legal Entity Representative (Required on EVERY Page)		
Printed Name and Title of Legal Entity Representative (Required on EVERY Page)		Date
Nonette M. Johnson - Administrator		5-1-2017

DEPARTMENT USE ONLY - HOMES MAY NOT WRITE BELOW THIS LINE!

The above plan of correction is approved as of 5/17/17
 (Date)

The above plan of correction was approved by NAS
 (Initials)

Plan of correction implementation status as of 5/17/17
 (Date)

- Fully Implemented
- Partially Implemented - Adequate Progress
- Partially Implemented - Inadequate Progress
- Not Implemented